

CERTIFICATE OF COMPLIANCE

Certificate Number 20180614-MP1537
Report Reference MP1537-20180606
Issue Date 2018-JUNE-14

Issued to: FIREYE INC
3 Manchester Rd
Derry, NH 03038-3031 USA

**This is to certify that
representative samples of**

Controls, Primary Safety
Insight Series 4 Flame Scanners, Model Numbers 95UVS4-1, 95IRS4-1, 95UVS4-2, 95IRS4-2, with or without cable assembly 59-547; 95UVS4-1WINC, 95IRS4-1WINC, 95UVS4E-1WINC, and 95IRS4E-1WINC, with or without cable assembly 59-608; 95UVS4-1CEX, 95IRS4-1CEX, 95UVS4-2CEX, and 95IRS4-2CEX.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


ANSI/UL 60730-2-5 / CSA C22.2 No. 60730-2-5, Automatic Electrical Controls for Household and Similar Use, Part 2-5: Particular Requirements for Automatic Electrical Burner Control Systems and IEC 61508 Parts 1-7 in accordance with SIL 3.

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

