



**PRODUCT GUIDE
SPECIFICATION**

**FIREYE PPC6000 PARALLEL
POSITIONING SYSTEM
WITH BURNERLOGIX
FLAME SAFEGUARD
BURNER MANAGEMENT**

1 GENERAL OVERVIEW

1.1.1. BURNER MANAGEMENT

1.1.2. Each burner shall be equipped with a Micro-processor Based Burner Management Flame Safeguard Control System. The control shall provide: (1) automatic sequencing of the boiler system through prepurge, pilot trial for ignition (PTFI), main trial for ignition (MTFI), run (AUTO), and post purge. (2) flame proving and lockout on flame failure during PTFI, MTFI, and AUTO.

1.1.3. The control system shall be provided by Fireeye or written approved equal.

2. PARALLEL POSITIONING CONTROL

2.1.1. Each burner shall be equipped with a state of the art microprocessor based stand alone parallel positioning control. The control shall be constructed utilizing surface mount technology thus reducing panel space requirements

2.1.2. The control system shall be provided by Fireeye or written approved equal.

3. CODES AND STANDARDS

3.1.1. The control shall be listed by Underwriters Laboratories in accordance with US and Canadian standards and Factory Mutual for its intended purposes.

3.1.2. The control shall be in compliance with ASME/CSD-1.

3.1.3. The control shall be in compliance with NFPA 85, Boiler and Combustion Systems Hazards code.



4. PARALLEL POSITIONING SYSTEM

4.1.1. SYSTEM HARDWARE MAIN CONTROLLER

4.1.2. Each burner shall be equipped with a microprocessor based fully functional stand alone parallel positioning system of surface mount design to reduce cabinet space.

4.1.3. The combustion control system shall be interlocked with the flame safeguard system via hard wired dry (volt free) contact. The contact shall be wired in such a manner as to assure a safety shut down and lock out in the event of a safety related fault.

4.1.4. The basic controller shall be capable of powering up to ten servomotors directly from the main controller. Servomotors will be of the low voltage type and controlled by secure CANbus communications via four wire cable.

4.1.5. Servomotors in the following torque ranges shall be available; 1 ft/lb, 3 ft/lb, 9 ft/lb, 15 ft/lb, 30 ft/lb. Servomotors 9 ft/lb and above will be of NEMA4 design.

4.1.6. The basic system shall include sequencing for up to four boilers without need for an external "plant master" controller. The sequence of boilers shall be adjustable and allow for different sequences depending on which boiler is designated as lead. Adjustable on and off delays shall be included to prevent short cycling. The sequencing system will include fully adjustable lag start and stop points based upon lead firing rate. Adjustable internal timers shall be available so as to reduce lag boiler short cycling.

4.1.7. The main control shall contain a user programmable function block programming section for custom applications. The custom blocks shall not overwrite the factory default program. In the event that the custom program becomes corrupted, the user shall be able to recall the factory default program via the keypad display.

4.1.8. Each parallel positioning control will have up to four independent fuel profiles. Profiles will not be limited to specific fuels, that is, all four could utilize the same servomotors for various

operating conditions or fuel availability. Each profile shall have up to a minimum twenty four (24) points.

4.1.9. Two independent PID control loops shall be available to optimize the response of the combustion control to various load conditions. The operating PID shall be selected via digital input.

4.1.10. The combustion control system shall be capable of interfacing to third party systems via external PROFIBUS or MODBUS-RTU gateways.

4.1.11. The combustion control system shall have a stand alone Windows® based software package for monitor, control and data logging via RS485 interface

4.1.12. All connections to the main controller will be via un-pluggable connectors eliminating the need for a separate wiring base.

4.1.13. The main controller shall be capable of mounting in any orientation without compromising system temperature ratings. The control system shall operate within the following limits:

- Temperature: 32qF to 140qF (0qC to 60qC)
- Humidity: 0% to 85% Non-condensing
- Voltage: 120/230 VAC (+10%, -15%) 50/60 Hz
- Power Consumption: 60 VA maximum
- 0.5G continuous vibration

4.1.14. Four safety rated digital/analog inputs shall be provided on the main controller. These inputs shall be configurable for, but not limited to, the following; Set point 1 or 2 selection, Lead Boiler selection, Alarm only or shut down function, Low fire hold, Purge hold. Digital inputs shall be configurable via optional software to provide analog input functions for custom applications. These functions may include, but are not limited to, Feed water control, Draft control, Stack temperature alarm/shut down, Soot blowing function.

4.1.15. An auxiliary modulation input shall be furnished to allow for remote modulation from Building Automation Systems or other systems.

5. KEYPAD DISPLAY



5.1.1. Each combustion control system shall be equipped with a NEMA4 two line vacuum florescent keypad display. The keypad display will provide all relevant information during commissioning and operation. The keypad display shall indicate Steam pressure, Boiler firing rate, Boiler status (lead, lag), Boiler efficiency, Boiler set point, Fuel valve position, Air damper(s) position, VFD speed, Hours run per profile, Modulation status (auto/man) and any Faults present or clearable. All programming of the combustion control shall be done via the keypad display. Programming via external devices such as laptops or special software shall not be accepted.

5.1.2. The keypad display shall automatically store all operating and fuel air ratio information so as in the event the control fails, all operational information can be downloaded to a new control.

5.1.3. The keypad display will incorporate three levels of passwords for protection against unauthorized changes. One level shall be for operators and prohibit the access to any safety critical settings.

5.1.4. The keypad display will include an Engineer's key for access to internal variables for system diagnostics.

5.1.5. The keypad display will log 100 faults with a date and time stamp of when the fault occurred, cleared and was restarted. This information shall be available via the Engineers key as well as via communications.

5.1.6. The combustion control system shall be capable of operating without the keypad display.

6. VARIABLE SPEED DRIVE

6.1.1. The combustion control system shall have provisions for utilizing a Variable Speed Drive for combustion air.

6.1.2. The associated controller card shall fit within the combustion control so as not to require additional panel space.

6.1.3. The VSD card shall include two (2) 4-20mA outputs for VSD with either 4-20mA or encoder feedback signals.

6.1.4. The VSD card shall also include one (1) 4-20 mA output for use with customizable function blocks.

6.1.5. The VSD card shall incorporate two (2) low voltage (volt free) relay outputs for use with customizable function blocks.

7. OXYGEN TRIM

7.1.1. The combustion control system shall incorporate an in situ Zirconia Oxide heated exhaust gas probe. The probe design shall be such that particulate in the flue gas stream does not impact directly on the probe filter thus increasing uptime.

7.1.2. The Zirconia Oxide probe shall not employ any pumps or gas preparation equipment such as solid state coolers. No probe condensate pumps will be permitted.

7.1.3. The keypad display will indicate; Oxygen level, Net stack temperature, Combustion efficiency, Ambient air temperature, Calculated CO2 levels and amount of trim applied. An Engineers key will display O2 values during commissioning.

7.1.4. The oxygen probe shall be connected to the combustion control via secure CANbus communications from the oxygen interface module.

7.1.5. The oxygen interface module shall be housed in a NEMA4 enclosure for mounting outside the control cabinet to reduce panel space and facilitate field wiring.

7.1.6. The oxygen trim interface module shall be capable of accepting up to two (2) third party 4-20mA probe signals.

8. FLAME SAFEGUARD CONTROL

8.1.1. Major functions of the boiler management system shall have the following capabilities to provide:

8.1.2. User selectable burner operating parameters such as purge time, PTFI & MTFI time, post purge time, and specific operation of the various interlocks.



8.1.3. All burner operating parameters become permanent after 8 hours of main burner on time.

8.1.4. An adaptive Infrared flame scanning detection system where the characteristics of the pilot and main flames are separately learned in order to set the on/off thresholds and optimizing safety.

8.1.5. Flame proving and lockout on flame failure during PTFI, MTFI and AUTO.

8.1.6. The control shall have a non-volatile memory which allows it to remember burner history and present position, even after a power interruption.

8.1.7. The control shall provide a check-run switch to allow a qualified service technician to halt the burner sequence in any of five different positions:

- High fire purge
- Low fire purge
- Pilot trial for ignition
- Main trial for ignition
- Low fire (burner on)

8.1.8. Alpha-numeric multi-line LCD or VFD display to continually indicate operating parameters as well as first out annunciation.

8.1.9. SMART light emitting diodes (LED's) to provide operating status as well as lockout code identification.

8.1.10. Damper motor high and low fire damper motor position proving.

8.1.11. Non-volatile lockout and history files with the last 10 lockouts readable through the optional display.

8.1.12. Field replaceable 10 amp fuse in the fuel valve and ignition circuit for short circuit protection.

8.1.13. The control system shall operate within the following limits:

- Temperature: -40qF to 140qF (-40qC to 60qC)
- Humidity: 0% to 85% Non-condensing
- Voltage: 120 VAC (+10%, -15%) 50/60 Hz
- Power Consumption: 20 VA maximum

- 2000 VA maximum connected load
- 0.5G continuous vibration

8.1.14. The control shall have the following storage

8.1.15. temperature limits:

- Temperature: -40qF to 158qF (-40qC to 70qC)
- Humidity: 0% to 85% Non-condensing

9. DISPLAY MODULE

9.1.1. The Display Module shall consist of a two (2) line with sixteen (16) characters per line liquid crystal (LCD) or vacuum fluorescent (VFD) display and multi-functional 4-key, positive action keypad.

9.1.2. The display module will provide the user the option of displaying messages in one (1) of six (6) languages.

9.1.3. The messages shall be clear, concise information concerning system timing, present burner sequence position, lockout causes (including wiring base terminal designations) and historical data.

9.1.4. During the firing cycle, a constant read-out of the flame signal will be displayed.

9.1.5. The Display Module shall incorporate a four (4) key keypad to allow the user direct local access to the following information:

- Number of burner operating cycles.
- Number of burner lockouts.
- Number of system hours.
- Reason for the last ten lockout along with the Burner cycle and burner hour when the lockout occurred.
- Average pilot and main flame signal strength.
- Status of high fire and low fire end switches.

9.1.6. The LCD keypad/display module shall operate within the following temperature limits: -4qF to 140qF (-20qC to 60qC).

9.1.7. The VFD keypad/display module shall operate within the following temperature limits: -40qF to 140qF (-40C to 60qC).

9.1.7.1. The keypad/display module shall have the capability to be remotely mounted to a distance



of 8 feet (2.43 meters).

9.1.8. When remotely mounted, both the LCD and VFD display modules shall provide NEMA 4 protection.

10. WIRING BASE

10.1.1. A pre-wired or terminal block wiring base shall be provided which will allow for all system terminations to be completely wired prior to the installation of the control. The control shall be removable or replaceable without removing any wiring terminations.

10.1.2. The wiring base shall provide line voltage terminal inputs from direct connection of limit and operating controls, fuel valve interlock, damper position interlocks, running interlocks (such as air flow, gas pressure, oil pressure, oil temperature), burner motor, ignition, pilot valves, main fuel valves, firing rate motor, and alarm.

10.1.3. The pre-wired wiring base shall be provided with 4 foot leads sufficiently sized to carry the load currents and each wired is labeled in accordance with its function.

10.1.4. The terminal block wiring base shall allow the user to measure the voltages and signals on any of the terminals without having to remove the control from the wiring base.

11. SYSTEM SOFTWARE

11.1.1. PROGRAMMER PARAMETERS

11.1.2. The control shall provide to the user a range of keypad selectable operational parameters that will allow the control to be properly suited to meet the application requirement. These parameters shall include purge time, PTFI/MTFI timings, post purge time, terminal 6 operation, M-8 prove open, M-D prove open, 3-P prove open, prove M-D during TFI, baud rate and unit address.

11.1.3. User programmable safety parameters become permanent after 8 hours of main burner operation.

12. SEQUENCE OF OPERATION

12.1.1. The control shall accomplish a safe start

component check during each start. This shall prevent the burner from firing under any condition which causes the flame relay to assume and hold its energized position due to the presence of an

12.1.2. actual flame, a flame simulating component failure or mechanical failure.

12.1.3. A purge period of not less than 30 seconds with a damper driven to the open position and an interlock circuit provided to prove air flow rate during the purge period. A starting interlock circuit is required to prove that the burner equipment is in the low fire position at

12.1.4. the time of ignition, plus an interlock to prove air flow during the purge and firing cycle.

12.1.5. Limited trial-for-ignition of pilot flame restricted to 10 seconds, trial-for-main flame restricted to 10 or 15 seconds (selectable) for oil or gas.

12.1.6. Safety shutdown following flame failure, with fuel and ignition circuits de-energized in not more than 4 seconds.

12.1.7. A post purge of 15 seconds following a shutdown.

12.1.8. The system shall recycle automatically under control of the operating control and when power is restored following a power failure. Manual reset shall be required following any safety lockout, even after a power failure. When in a lockout condition, power interruptions will not recycle the control.

12.1.9. The control shall provide a check-run switch which shall allow a qualified service technician to halt the burner sequence in any of four different positions:

- High fire purge
- Low fire purge
- Pilot trial for ignition
- Main trial for ignition
- Low fire (burner on)

13. SAFETY PROVISIONS

13.1.1. A self diagnostic circuit within the control will identify module failures and an appropriate message will be displayed for servicing. This circuit will cause a safety shutdown should any component in the control fail. For example, if the chassis section is malfunctioning, the



Display module will display the message "LOCKOUT CHECK CHASSIS"

13.1.2. The control will continually test the status of all safety critical loads (ignition transformer, pilot fuel valve, main fuel valve) to insure they are operating properly.

16.1.2. The installing contractor shall be responsible for insuring that the conduit size

and wire size, type and quantities are applicable for the installation and equipment supplied

14. ANNUNCIATION AND DIAGNOSTICS

14.1.1. First out annunciation with burner sequence position indication.

14.1.2. Indication of failures at start up or during normal sequence operation.

14.1.3. Test itself for failure, detect and isolate an alarm, and report internal circuit faults.

14.1.4. Multiple language text description of system fault.

14.1.5. Maintain the last 10 faults with burner hour and burner cycle stamp in historical memory, accessible through the display or remote communications.

15. REMOTE COMMUNICATIONS

15.1.1. The burner management system shall operate either as an independent stand alone control, or as part of a distributed system network. In a distributed system network, multiple controllers are connected via a data link (a single twisted shielded pair wire) to a Supervisory Master Controller (eg: personal computer, PLC, building management system).

15.1.2. Up to 31 burner management controls can be connected together in a multi-drop configuration on a single data link.

15.1.3. The communication protocol for the distributed system network shall be MODBUS-RTU.

15.1.4. The distributed network shall offer selectable baud rates, 4800, 9600 or 19200 bits per second.

16. WIRING

16.1.1. All wiring shall be in accordance with National Electrical Code and local electrical codes.



7. PRODUCT INFORMATION

Parallel Positioning System

Part Number Description:

PPC6000	Stand alone parallel positioning controller. Up to 10 servomotors, two PID, Four digital/Analog inputs, Function block programming.
NX610	Keypad display for PPC6000 parallel positioning control with Fault History and Upload/Download backup).
NXC04	CANbus Servomotor 3ft/lb, 24 volt, NEMA1 For use with PPC6000
NXC12	CANbus Servomotor 9ft/lb, 24 volt, NEMA3S. For use with PPC6000
NXC20	CANbus Servomotor 15ft/lb, 24 volt, NEMA3S. For use with PPC6000
NXC40	CANbus Servomotor 30ft/lb, 24 volt, NEMA4. For use with PPC6000
NXDBVSD	Variable Speed Drive daughter board, two VSD, One analog output, two Low Voltage relay outputs for use with PPC6000
NXO2INT	Oxygen Probe Interface module for in situ Zirconia Oxide probe. Two 4-20mA third party probe inputs
PXMS***	Steam Pressure sensor. Ranges available are: 15, 200 and 300 PSI. Other ranges, consult factory.

Burner management

Part Number Description:

YB110**	Flame Safeguard Chassis and Amplifier type. (Specify IR for AutoCheck Infrared, UV for non self-check UV, UVSC for self-check UV).
YP1**	Programmer Module for Flame Safeguard Control. (Specify YP100, YP102, YP138 or YP113 to meet application requirements).
60-2810-1	Pre-wired wiring base for Flame Safeguard Control (surface mounted - UL listed).
60-2812-1	Closed Terminal block wiring base for Flame Safeguard Control (cabinet mounted - UL recognized).
60-2814-1	Open Terminal block wiring base for Flame Safeguard Control (cabinet mounted - UL recognized).
BLL510	LCD Keypad/Display Module.
BLV512	VFD Keypad/Display Module.
48PT2	Infrared scanner
UV1A	Ultra-violet (UV) scanner, non-self-check
45UV5-1009	Ultra-violet (UV) scanner, self-check
55UV5-1009	Ultra-violet (UV) scanner, self-check for hazardous locations