



FIREYE Inc.  
3 Manchester Road  
Derry, NH 03038 USA  
Tel: (603) 432-4100  
Fax: (603) 432-1570

## Addendum:



When using an NXTSD407 or NXTSD413 touchscreen with a PPC4000 programmed with main firmware version 3.9, the system must not use a servo with address set to "1". All other servo addresses (2 thru 10) are fine.

To learn how to set the servo address, please consult the NEX-3004/20/50 technical document.